


CERTIFICATE

No. Z2 116996 0008 Rev. 00

Holder of Certificate: **Sunphase Solar Energy**
No. 35, Cuihu Road,
Rare Earth High-tech Zone,
014030 Baotou City, Inner Mongolia
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062239605-00

Valid until: 2027-11-09

Date, 2022-11-14



(Zhulin Zhang)

CERTIFICATE

No. Z2 116996 0008 Rev. 00

Model(s):

182 cell modules
144 cells
Primax SPH-xxxW-M10 (xxx=530 to 555 in steps of 5
120 cells
Primax SPH-xxxW-M10, xxx=550 to 570 in steps of 5
144 cells

xxx stands for rated output power at STC

Parameters:

Safety Class:	Class II
Max. system voltage:	1500V DC
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790.
PID Test Condition:	-1500V, 96 h, 85 % RH, 85°C
PID test method is according to test method a of IEC TS 62804-1:2015	

Tested according to:

IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016
PPP 58042B:2015